

ग्रामीण अभियन्त्रण सेवा, कुशीनगर

सेवा में,

प्रबन्धक,

पी.एन.नेशनल पब्लिक स्कूल

एन.एच. 28 फाजिलनगर, महुअवाकाटा

कुशीनगर

विषय. पी एन नेशनल पब्लिक स्कूल एन एच. 28 फाजिलनगर महुअवाकाटा, कुशीनगर के भवन का नेशनल बिल्डिंग के सापेक्ष प्रमाण पत्र के सम्बन्ध में।

सन्दर्भ.आपका पत्र संख्या दृ शून्य दिनांक 23/06/2017.

उपरोक्त संदर्भित पत्र के सम्बन्ध में इस खण्ड के अवर अभियन्ता के साथ निरीक्षण किया गया है निरीक्षणोपरान्त भवन बिल्डिंग कोड के रिमार्क कालम के अनुसार पायी गयी।

Sl. No.	Items	Standard	Specification	Remarks
1	Height	2.75 M	N.B.C. 2005 Column-12.18.1.1	3.0 M
2	Bathroom Height	2.1 M	N.B.C. Clause- 12.4.1	3.0 M
3	Height of Plinth	0.45 M	N.B.C. Clause- 12.1.1	0.45 M
4	Stair Width	1.50 M	N.B.C. Clause- 12.18.1.1	1.80 M
5	Lighting and Ventilation room	1/10 floor area	N.B.C. Clause- as per N.B.C. 2005 Clause- 15.1.2	1/10 Floor area
6	Fire and life safety	Certified by PHO	Kushinagar	Available
7	Roofs	R.C.C. flate Roof	As per N.B.C. 2005 clause- 12.19.1	R.C.C. Heat Proof
8	Structure	RCC column and Beam	As per N.B.C. 2005 clause- 12.19.1	RCC column and Beam

दिनांक 28/6/17

PRINCIPAL

P.N. NATIONAL PUBLIC SCHOOL
HUAWA KATA
KUSHINAGAR

DE

C.S.

सहायक अभियन्ता

ग्रामीण अभियन्त्रण सेवा,

कुशीनगर

MANAGER
P.N. NATIONAL PUBLIC SCHOOL
NH-28 MAHUAWA KATA
KUSHINAGAR

